Sureserve Compliance Fire Ltd
Wilson House, North Heath Lane, Horsham, RH12 5QE

Non-Technical Checks

Wandle Housing Association Limited	**Job Number:**	10446186	**Engineer:**	Ahmed, Farhan
UPRN: 1543B0000000	**Visit Date:**	04/07/2025		
Chloe Court, Flats 1-22 [HR6]	**Arrival Time:**	11:45		
Bournemouth Road	**Departure Time:**	12:32		
Peckham, London	**Order Reference:**			
SE15 4UN				

AOV Control System MONTHLY INSPECTION CHECKLIST	Yes	**Status:**	Pass
Panel is Fault Free:	Yes	**System Triggered when Activated:**	Yes
All Relevant Vents Opened:	Yes	**System Reset & Fault Free:**	Yes
Mechanical System Only. Fans/Powered Exhaust Operational and Activated:	Yes		

Comments / Details and Locations of Faults Found:

All the vents are tested via control switch, All working fine.

Dry Riser MONTHLY INSPECTION CHECKLIST	Yes	**Status:**	Pass
Outlet | Valves in Place:	Yes	**Inlet | Serviced Within the Last 6 Months:**	No
Outlet | Cabinets Glass and Doors Intact:	Yes	**Inlet | Glass or Door Intact:**	Yes
Outlet | Valves Strapped and Padlocked:	N/A	**Inlet | Location Identifying Signage in Place:**	Yes
Outlet | Spindle Wheel & Valve Caps in Place:	No	**Inlet | Valves and Drain Valves Caps in Place:**	No
Outlet | Damage/Cracks to Visable Riser Pipes:	No		
Outlet | Location Identifying Signage in Place:	Yes		
Outlet | AIR Release Valve Free of Blockage:	No		

Comments / Details and Locations of Faults Found:

have visually checked All the Dry Risers, Can't been able to open the riser door to check inside as don't have the keys also couldn't find any log regarding servicing of the system.

Fire Alarm System MONTHLY INSPECTION CHECKLIST	Yes	**Status:**	Pass
Panel is Fault Free:	Yes	**System Triggered when Activated:**	Yes
If Connected Fire Doors Closed on Activation:	N/A	**Fire Alarm Sounders Activated:**	Yes
If Connected Smoke Control System Activated:	N/A		
If Connected Call Centre Received Signal:	N/A		

Comments / Details and Locations of Faults Found:

weekly test carried out on fire panel, All working fine.

Engineer:	**Customer:**

Non-Technical Checks

Ahmed, Farhan	000